



CLIENT: Metro Green
100 Oak Street
Mt. Vernon, NY 10550

DATE: March 23rd, 2016
LAB#: 16257

PROJECT: Information of Client

SAMPLE ID: #1 Gap Graded 3/4" "Stone": Recycled Material


TECHNICIAN: T. DeMaio

Delivered by Client: March 17, 2016

SIEVE SIZE	% PASSING
1 1/2"	100
1"	57.9
3/4"	11.8
1/2"	2.7
3/8"	1.2
#4	0

Respectfully submitted,
CERTIFIED TESTING LABORATORIES, INC.

Richard J. Zaloum
Richard J. Zaloum, P.E.



RZ/dk