



**Sieve Analysis Report**

<b>CLIENT:</b>	Metro Green 100A Oak Street Mt. Vernon, NY 10550	<b>DATE:</b>	April 4, 2018
<b>PROJECT:</b>	100A Oak Street Mt. Vernon, NY 10550	<b>LAB NO:</b>	16257
<b>SAMPLE ID:</b>	#2 screened fill	<b>TIME IN:</b>	09:00AM
<b>RECEIVED:</b>	3-28-18 Del by client Anthony	<b>TIME OUT:</b>	12:00PM
<b>INSPECTOR:</b>	Glenn Riegel		

**EXAMINED WITH THE FOLLOWING RESULTS:** AASHTO T11 & T27; See also attached curve.

RESULTS	
Sieve Size	% Passing
1"	97.0
3/4"	94.9
1/2"	89.7
3/8"	85.6
#4	73.7
#10	66.0
#20	56.7
#40	46.1
#60	85.9
#80	30.1
#100	28.0
#200	20.6

<b>EQUIPMENT USED:</b>	Sieves; SN CTL-001/ATL Shaker, SN CTL-001/ATL
------------------------	--

NOTE: No Proctor Report, samples will be retained for 30 days; if required.

Respectfully submitted,  
CERTIFIED TESTING LABORATORIES, INC.

*Richard J. Zaloum*  
Richard J. Zaloum, PE




RZ/dk

CERTIFIED TESTING LABORATORIES, INC. 754 East Fairview Street Bethlehem, PA 18018 Area Code 610 865-2674

### AGGREGATE GRADING CHART

SCREEN OPENING IN INCHES



Client: Metro Green

Sample Identification: #2 Screened Fill

Project: 100A Oak Street

Mr. Vernon NY

DATE: April 2, 2018

