



CTL

CERTIFIED TESTING LABORATORIES, INC.

Sieve Analysis Report

CLIENT: Angelo Maiorano
Metro Green LLC
100A Oak Street
Mount Vernon, NY 10550

DATE: 02-17-2022

PROJECT: 100A Oak Street, Mount Vernon NY
NY 10550

LAB NO: 16257

SAMPLE ID: # 4 Stone Dust

TIME IN: 7:00AM

RECEIVED: 02-16-2022

TIME OUT: 3:00PM

INSPECTOR: D. Duarte & J. Appiah CET

Sieve Size	Grain Size	Grams		RESULTS	
		Weight Retained	% Retained	Cumulative % Retain	% Passing
1"	25.4	0	0.00	0.00	100.00
3/4"	19.05	0	0.00	0.00	100.00
1/2"	12.7	0	0.00	0.00	100.00
3/8"	9.525	1.2	0.13	0.13	99.87
#4 - 1/4"	6.35	91.6	9.84	9.97	90.03
#10 - 1/10"	2.45	238.7	25.64	35.61	64.39
#60 - 1/60"	0.423	422.8	45.41	81.02	18.98
#100 - 1/100"	0.254	82.9	8.90	89.92	10.08
#200 - 1/200"	0.127	7.9	0.85	90.77	9.23
Pan		84.5	9.08	99.85	0.15

Wet Soil (Ws): 1000 g
 Dry Soil (Ds): 931 g
 Moisture Content: 6.9 %

EQUIPMENT USED:	Sieves, SN: CTL-SIV003 / CTLSIV038 Shaker, SN: CFMSS002, Scale SN: CTL-SCL-003
------------------------	---



Respectfully submitted,
 CERTIFIED TESTING LABORATORIES, INC
 Kirt Dobbins, PE

KD/dk

CTL SOF S-3
 6/1/12
 RZ



CTL

CERTIFIED TESTING LABORATORIES, INC.

PICTURE NO.: 4

CLIENT: Metro Green LLC

DATE: 02-17-2022

PROJECT: 100A Oak Street, Mount Vernon NY NY 10550

TIME IN: 7:00 AM


CONTRACTOR: Metro Green LLC

TIME OUT: 3:00 PM

ARCHITECT/ENGINEER: N/A

INSPECTOR: D. Duarte & J. Appiah CET

Sieve Size	Grain Size	Grams		RESULTS	
		Weight Retained	% Retained	Cumulative % Retain	% Passing
1"	25.4	0	0.00	0.00	100.00
3/4"	19.05	0	0.00	0.00	100.00
1/2"	12.7	0	0.00	0.00	100.00
3/8"	9.525	1.2	0.13	0.13	99.87
#4 - 1.4"	6.35	91.6	9.84	9.97	90.03
#10 - 1.18"	2.45	238.7	25.64	35.61	64.39
#60 - 1.60"	0.423	422.8	45.41	81.02	18.98
#100 - 1.100"	0.254	82.9	8.90	89.92	10.08
#200 - 1.200"	0.127	7.9	0.85	90.77	9.23
Pan		84.5	9.08	99.85	0.15



PICTURE OF: Test # 4

FLOOR: N/A

LOCATION ON FLOOR: N/A

DATE: 02-17-2022

CTL SOF-35
4/10/2020
KD

THIS INSPECTION REPORT RELATES ONLY TO THE ITEMS INSPECTED/TESTED AS MENTIONED ABOVE. All reports are the confidential property of Clients, and information contained may not be published or reproduced, pending our written approval. 140 Marbledale Road ° Tuckahoe, New York 10707 ° (718) 824-1616 ° Fax (914) 335-3089